

OMRON

MODEL S8VK-WA (2000W)

SWITCHING POWER SUPPLY

INSTRUCTION MANUAL

Thank you for purchasing the S8VK-WA. This Instruction Manual describes the functions, performance, and application methods required to use the S8VK-WA.

- Make sure that a specialist with electric knowledge operates the S8VK-WA.
- Read and understand this Instruction Manual, and use the Product with enough understanding.

Keep this Instruction Manual close at hand and use it for reference during operation.

- See the linked Instruction Manual.
- Siehe die verlinkte Bedienungsanleitung.
- Voir le manuel d'instructions lié.
- Vedere il manuale di istruzioni collegato.
- Consulte el manual de instrucciones vinculado.
- 请参阅链接的使用说明书。



OMRON Corporation
© OMRON Corporation 2023 All Rights Reserved.

Safety Precautions

Key to Warning Symbols

WARNING Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. Additionally, there may be significant property damage.

CAUTION Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury or in property damage.

Warning Symbols

WARNING

- Be sure to use the recommended circuit-breaker or fuse to avoid risk of fire or electric shock in case of Product failure.

When connecting to the terminal block, insert the wire straight into the terminal block until the end touches the terminal block. Otherwise, the wire may come loose, resulting in electric shock.


CAUTION

- Do not disassemble, modify, or repair the Product or touch the interior of the Product. Doing so may result in minor electric shock, fire, or Product failure.
- Do not touch the Product while power is being supplied or immediately after power is turned OFF. Doing so may result in minor burns.
- Do not touch the terminals while power is being supplied. Doing so may result in minor injury due to electric shock. Working voltage of 384 V max. is generated inside the Product during power-ON and remains continuous for 30 seconds after power-OFF.
- Do not allow any pieces of metal or conductors or any clippings or cuttings resulting from installation work to enter the Product. Doing so may result in minor electric shock, fire, or Product failure.
- If the circuit-breaker trips or the fuse blows, a serious malfunction may have occurred in the equipment. In that case, do not turn the input back ON.

Nomenclature and Power Distribution System

Nomenclature

S8VK-WA20224
S8VK-WA20248




- Input terminal (L1/+)
- Input terminal (L2)
- Input terminal (L3/-)
- PE (protective earthing) terminal (PE (protective earthing) terminal complied with safety standards. Connect the ground completely.)
- DC output terminal (+V)
- DC output terminal (-V)
- INPUT OK indicator (INPUT OK: green)
- lout > 100% indicator (lout > 100%: yellow)
- DC OK indicator (DC OK: green)
- Output voltage adjuster (V.ADJ)
- lout > 100% signal output terminal
- DC OK signal output terminal
- COM terminal
- Parallel operation switch (OPERATION)


Power Distribution System

- Connect the input as shown in the figure below.
- For 3-phase 4-wire system, do not connect the neutral wire, but connect the other 3 wires to L1/+, L2 and L3/-.


Input wiring (TN-S/TN-C/TT/IT)



Input wiring (2-phase/Single-phase)




Input wiring (DC)



Precautions for Safe Use

Installing/Storage Environment

- Store the Product at a temperature of -40 to 85°C and a humidity of 95% or less.
- Take adequate measures to ensure proper heat dissipation to increase the long-term reliability of the Product. The Product is cooled by natural convection. Mount it in such a way that the surrounding air around the Product is convected.



- The derating curve is different from that for standard mounting if the horizontal separation is less than 15 mm.
- The internal parts may occasionally deteriorate or be damaged. Do not use the Product under conditions that exceed the range of the derating curve.
- Use the Product at a humidity of 95% or less.
- Avoid places where the Product is subjected to direct sunlight.
- Do not use the Product in locations where liquids, foreign matter, or corrosive gases may enter the interior of the Product.
- Avoid places subject to shock or vibration. Install the Product away from contactors and other parts and devices that are sources of vibration.
- If the Product is used in an area with excessive electronic noise or surge, be sure to separate the Product as far as possible from the noise and surge sources.
- The internal parts may occasionally deteriorate and be broken due to adverse heat radiation. Do not loosen the screws on the Product.

Recommended Circuit-breakers and Fuses

- Be sure to use the recommended circuit-breaker or fuse to avoid risk of fire or electric shock in case of Product failure.
- To comply with safety standards and to ensure safety when using the Product, be sure to use the following recommended circuit-breakers or fuses to connect the input to the Product.
- Connect the input as shown in the figure of Power Distribution System.
- A circuit breaker or fuse can be changed only by a fully trained or skilled operator.

Model	Input	Recommended Items (per one Product)
S8VK-WA202□□	3-phase	Circuit breaker: 240 VAC min., 18 to 40 A, Type B or C characteristics
	Single-phase and 2-phase	Circuit breaker: 240 VAC min., 30 to 40 A, Type B or C characteristics
	DC	Fuse: Fast-acting type, 390 VDC min., 30 A

Note: When using multiple units with a connecting wire, select a circuit breaker or fuse in consideration of the input current and inrush current. If you install a circuit breaker upstream of the recommended circuit breaker or fuse, observe its ratings and tripping characteristics to ensure that the circuit breaker does not trip at the same time or before them. This Product has been certified and conformity assessed by test with the following BCP (Branch Circuit Protection): Eaton Electrical Ltd., FAZ-D40/3-NA, 40 A, 240 VAC (UL certified CGN: DIVQ/7)

Installation/Wiring

- Connect the ground completely. A protective earthing terminal complied with safety standards is used. Electric shock or malfunction may occur if the ground is not connected completely.
- Minor fire may possibly occur. Ensure that input and output terminals are wired correctly.
- Minor fire may possibly occur. When replacing with the Product, be sure to check the equipment voltage and use the appropriate Product.
- To prevent wiring materials from smoking or ignition, confirm wire ratings and use the wiring materials given in the following table.

Recommend Wire:

Terminal	Model	Recommend Wire	
		(mm ²)	(AWG)
Input	S8VK-WA202□□	2 to 2.5	14
Output	S8VK-WA202□□ ¹⁾	6 to 16	10 to 6
Signal output/COM	S8VK-WA202□□	0.25 to 2.5	24 to 14
PE (protective earthing)	S8VK-WA202□□	2 to 2.5	14

- Note:
- Use stranded or solid copper wires; however, it should be noted that the solid wire can not be used at the output of S8VK-WA202□□.
 - Use heat-resistant wires of at least 60°C or 80/75°C for input lines only.
 - Be sure to simultaneously use multiple terminals and wires when the current exceeds either of the following ratings. Rated current (output terminal): 45 A per terminal. Current rating of wire (output): 65 A for 6 AWG, 50 A for 8 AWG, 35 A for 10 AWG

Stripping length

Recommend Wire Type	Ferrules length	Recommend Stripping length	
		Ferrules used	Ferrules not used
0.25 to 1.5 mm ² /AWG24 to 16	8 mm	10 mm	8 mm
	10 mm	12 mm	8 mm
2 to 2.5 mm ² /AWG14	10 mm	12 mm	10 mm
	6 mm ² /AWG10	18 mm	21 mm
8 to 10 mm ² /AWG8	18 mm	21 mm	18 mm
	14 to 16 mm ² /AWG6	Not recommended	Not recommended

- Do not apply more than 40 N (100 N for the output terminal block) force to the terminal block when you insert wiring or when you insert a flat-blade screwdriver into the release hole.
- Do not wire anything to the release holes.
- Do not tilt or twist a flat-blade screwdriver while it is inserted into a release hole on the terminal block. The terminal block may be damaged.
- Insert a flat-blade screwdriver into the release holes at an angle. The terminal block may be damaged if you insert the screwdriver straight in.
- Do not allow the flat-blade screwdriver to fall out while it is inserted into a release hole.
- Do not bend a wire more than its natural bending radius or pull on it with excessive force. Doing so may cause the wire disconnection.
- Do not insert more than one wire into each terminal insertion hole.
- Do not pre-solder the ends of the wires. Doing so will inhibit proper connection.
- If there is a possibility that the Unit will be subject to vibration or shock, use wires with ferrules or stranded wires.
- To allow heat to dissipate, always remove the sheet covering the Product for wiring before you turn ON the power.

Output Voltage Adjustment

- The output voltage adjuster (V.ADJ) may possibly be damaged if it is turned with unnecessary force. Do not turn the adjuster with excessive force.
- After completing output voltage adjustment, be sure that the output power or output current does not exceed the rated output power or rated output current.

INPUT OK Indicator

The INPUT OK indicator lights up when the input voltage exceeds the lower limit value of the permissible range. Note: The voltage may be applied even if the indicator does not light. Be sure to check the input voltage when performing wiring.

DC OK Indicator/Signal Output

The DC OK indicator lights up when the output voltage is more than 90% of the rated output voltage, and the internal MOS FET relay is conducted (turned ON).

Note:

- The output voltage may be generated even if the indicator does not light. Be sure to check the output voltage when connecting to the load.
- The signal output function monitors the voltage of the Product's output terminals. Be sure to measure the voltage of the load terminal when checking the accurate voltage status applied to the load.
- If the output voltage is set to less than 90% of the rated output voltage, the indicator may go off and the signal output may be turned OFF.

lout > 100% Indicator/Signal Output

The lout > 100% indicator lights up when the output current exceeds the rated output current, and the internal MOS FET relay is conducted (turned ON).

Specifications of the Signal Output Terminals

(Between DC OK Signal Output Terminal and COM Terminal, and between lout > 100% Signal Output Terminal and COM Terminal)
30 VDC max., 50 mA max., residual voltage of 2 V or less at ON and leakage current of 0.1 mA or less at OFF.

- The Product is not equipped with an internal current limiting circuit. Be sure that the current flowing to the signal output terminals does not exceed 50 mA.
- Be sure to check that the signal output terminals are working normally after wiring.

- See the Product catalog for details.

Precautions for Correct Use

Mounting

- Refer to Fig.1 for mounting and to the catalog for DIN track information.

Input Voltage Tolerance

Rating:

AC input Rated range: 200 to 240 VAC (3-phase/2-phase/Single-phase)

- Allowable AC input range: -15 to +10% (170 to 264 VAC)
 - For an input voltage of less than 200 VAC, reduce the load calculated with derating 0.5%/V.
- DC input Allowable range: 240 to 384 VDC
- For an input voltage of less than 280 VDC, reduce the load calculated with derating 1.0%/V.

Output Voltage Adjustment

Default Setting: Set at the rated voltage

Adjustment Range: Adjustable with "V.ADJ" (Ⓢ) on the front surface within the range shown in the table below. Turning clockwise increases the output voltage, and turning counterclockwise decreases the output voltage. Note: The output voltage may increase beyond the allowable voltage range when "V.ADJ" (Ⓢ) operation is performed. When adjusting the output voltage, check the output voltage of the Product and be sure that the load is not damaged.

Model	Adjustment Range
S8VK-WA20224	24 to 28 V
S8VK-WA20248	48 to 56 V

Dielectric Strength Test

The Product is designed to withstand 3,000 VAC for one minute between input terminals ① to ⑥ together and output terminals ⑧ to ⑭ together. When conducting the test, set the cutoff current for the withstand voltage test device to 20 mA.

Notes:

- If the full dielectric strength voltage of 3,000 VAC is applied or turned OFF using the switch on the tester, the generated impulse voltage may damage the Product. Use the adjustment on the tester to gradually increase and decrease the voltage.
- To prevent damage, always short all terminals before testing.

Insulation Resistance Test

When testing the insulation resistance, use a DC resistance meter at 500 VDC.

Note: To prevent damage, always short all terminals before testing.

Overload Protection

The overload protection circuit will automatically reduce the output voltage for short circuits and overcurrents to protect the Product from short-circuit currents and overcurrents. The output voltage is cut OFF if any of the following conditions occur.

- Current in excess of the rated value continues to flow for more than 5 seconds. (Parallel operation switch: SINGLE only)
 - Drop of output voltage under the overcurrent protection continues for more than 3 seconds.
- To reset the Product, leave the Product OFF for more than 3 minutes and then turn it ON again.

Notes:

- Internal parts may possibly deteriorate or be damaged if a short-circuited or overcurrent state continues during operation. Be sure to check that the lout > 100% indicator is not lit or the lout > 100% signal output is turned OFF before using.
- Internal parts may possibly deteriorate or be damaged if the Product is used for applications with frequent inrush current or overloading at the load end. Do not use the Product for such applications.
- Be sure to clear the cause of the overvoltage, before turning on the Product.

Only for the S8VK-WA20224 (for Terminal Block)

The overload protection function operates when a current exceeding 45 A continuously flows for 10 seconds or more at the respective output terminals. The maximum current of the terminals is limited to 45 A or less, and the output voltage also drops.

When the output current and output voltage fall within the rated range, the overload protection function is automatically cleared.

The output voltage will be cut OFF if it drops under the overcurrent protection and keeps on dropping for more than 3 seconds.

To reset the Product, leave the Product OFF for more than 3 minutes and then turn it ON again.

Notes:

- The output voltage at all terminals will drop if the overcurrent protection is applied to even one terminal.
- Make sure that the load connection wires are of the same length and thickness so that the same current flows through the wires.

Overvoltage Protection

When an excessive voltage that is approximately 130% of the rated output voltage or more is output, the output voltage is cut OFF, preventing the load from damage due to overvoltage.

To reset the Power Supply, turn off the input power for at least 3 minutes and then turn it on again.

Note: Do not turn ON the power again until the cause of the overvoltage has been removed.

Parallel Operation

Set the switch to "PARALLEL" if the units are in parallel operation.

SINGLE: The output current can use 100% of the rated output current.

PARALLEL: Overcurrent protection limits the output current to 80% of the rated output current.

In Case of No Output Signal

The overcurrent or overvoltage protection may be functioning. If a large surge voltage such as a lightning surge is applied to the input, the internal protection circuit may be functioning. Please contact us if there is still no output voltage even after checking the following two points.

- Checking the overcurrent protection
- Check (by removing the load cable) whether the load is in an overcurrent state (including short circuit). Turn off the input power once, leave it for at least 3 minutes, and then turn on the input power again.
- Checking both the overvoltage protection and internal protection
- Turn off the input power once, leave it for at least 3 minutes, and then turn on the input power again.

Conformance to EU Directives and UK legislation

Refer to the catalog and this instruction manual for details on the operating condition for compliance with the EMC Directive.

Disposal

When disposing of the Product, treat it as industrial waste.

Connecting Wires to the Push-In Plus Terminal Block

Connecting Wires with Ferrules and Solid Wires

Insert the solid wire or ferrule straight into the terminal block until the end strikes the terminal block. If it is difficult to connect a wire because it is too thin, use a flat-blade screwdriver in the same way as when connecting stranded wire.

Connecting Stranded Wires

Use the following procedure to connect the wires to the terminal block.

- Hold a flat-blade screwdriver at an angle and insert it into the release hole. The angle should be between 10° and 15°. If the flat-blade screwdriver is inserted correctly, you will feel the spring in the release hole.
- Insert the wire until it strikes the terminal block while inserting the flat-blade screwdriver into the terminal hole.
- Remove the flat-blade screwdriver from the release hole.

Checking Connections

- After the insertion, pull gently on the wire to make sure that it will not come off and that the wire is securely fastened to the terminal block.
- If you use the recommended ferrule, part of the conductor may be visible after the ferrule is inserted into the terminal block. Even in that state, the Product insulation distance is still satisfied.


Removing Wires from Push-In Plus Terminal Block

Use the following procedure to remove wires from the terminal block. The same method is used to remove stranded wires, solid wires, and ferrules.

- Hold a flat-blade screwdriver at an angle and insert it into the release hole.
- Remove the wire from the terminal insertion hole while inserting the flat-blade screwdriver into the release hole.
- Remove the flat-blade screwdriver from the release hole.

Recommended Flat-blade Screwdriver

Use a flat-blade screwdriver to connect and remove wires. Use the flat-blade screwdriver shown below.



Safety standards

EN/IEC 62477-1 and EN/IEC 61204-7

- DC output terminals (⑧ to ⑭) are electrically isolated from the input terminals (① to ⑥).
- Overvoltage category III (≤ 2,000 m) Overvoltage category II (2,000 m < and ≤ 3,000 m)
- This equipment is for protection class I.
- Climatic class 3K3
- Do not handle the S8VK-WA20248 with wet hands.
- UL 62368-1, EN 62368-1 and CSA C22.2 No.62368-1 According to Overvoltage category II.
- CSA C22.2 No.107.1

CAUTION: FOR USE IN A CONTROLLED ENVIRONMENT. REFER TO MANUAL FOR ENVIRONMENTAL CONDITIONS.

ATTENTION: POUR UTILISATION EN ATMOSPHERE CONTRÔLÉE. CONSULTER LA NOTICE TECHNIQUE.

Ambient temperature / Surrounding Air Temperature

Max. 55°C at 80% load, 40°C at 100% load (> 40°C Load derating: 1.33%/K)

● Pollution degree Use in pollution degree 2 environment.

DC Input

- Safety standards apply for a DC input with UL 62368-1, cUL/CSA C22.2 No.62368-1, EN/IEC 62368-1, EN/IEC 62477-1 and EN/IEC 61204-7.
- Input voltage: 240 to 384 VDC (< 280 VDC load derating: 1.0%/V)

Conformance to RCM

The Power Supply complies with RCM as an industrial device.

Suitability for Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

OMRON

OMRON Corporation
Components Division HQ.
Shioikoji Horikawa, Shimogyo-ku, Kyoto,
600-8530 Japan
Tel: (81)75-344-7231
Fax: (81)75-344-7149

Regional Headquarters

OMRON EUROPE B.V.
Vegalaan 67-69, 2132 JD Hoofddorp
The Netherlands
Tel: (31)2356-81-300
Fax: (31)2356-81-388

OMRON ELECTRONICS LLC
2895 Greenspoint Parkway, Suite 200
Hoffman Estates, IL 60169 U.S.A.
Tel: (1) 847-843-7900
Fax: (1) 847-843-7787

OMRON ASIA PACIFIC PTE. LTD.
No. 438A Alexandra Road # 05-05/08
(Lobby 2), Alexandra Technopark,
Singapore 119967
Tel: (65)6835-3011
Fax: (65)6835-4111

OMRON (CHINA) CO., LTD.
Room 2211, Bank of China Tower, 200
Yin Cheng Zhong Road, PuDong New
Area, Shanghai, 200120 China
Tel: (86)21-6023-0333
Fax: (86)21-5037-2388

Note: Specifications are subject to change without notice.

